



NATIONAL TYPE EVALUATION PROGRAM

Certificate of Conformance

for Weighing and Measuring Devices

For:

Indicating Element
Digital Electronic
Model: 855
 n_{max} : 10 000
Accuracy Class: III

***Submitted By: Contact Info. Updated December 2022**

Cardinal Scale Manufacturing Company
102 East Daugherty Street
Webb City, MO 64870
Tel: 417-673-4631 x 212
Fax: 417-673-2153
Contact: Thomas Schuller
Email: tschuller@cardet.com
Web site: www.cardet.com

Standard Features and Options

- Automatic Zero Tracking (AZT)
- Initial Zero Setting Mechanism (IZSM)
- Semi-Automatic (push button) Zero Setting Mechanism (SAZSM)
- AC Power (100 VAC to 240 VAC)
- DC Power (12 VDC)
- Gross Weight Display
- Alphanumeric Display
- Liquid Crystal Display (LCD)
- Communication (USB, RS232, WiFi, Bluetooth)
- Units of Measure (lb & kg)
- Motion Detection
- Multi-interval Capability
- Semi-Automatic (push-button) Tare
- Remote Printer Capability
- Power Saving Feature (Automatic Shutoff)
- Category 1 audit trail

This device was evaluated under the National Type Evaluation Program and was found to comply with the applicable technical requirements of *Handbook 44: Specifications, Tolerances and Other Technical Requirements for Weighing and Measuring Devices*. Evaluation results and device characteristics necessary for inspection and use in commerce are on the following pages. *Editorial changes, not affecting the type or metrological content, corrected this certificate.

Ivan Hankins
Chair, NCWM, Inc.

Hal Prince
Chair, NTEP Committee
Issued: May 16, 2022

1135 M Street, Suite 110 / Lincoln, Nebraska 68508

The National Conference on Weights and Measures (NCWM) does not approve, recommend, or endorse any proprietary product or material, either as a single item or as a class or group. Results shall not be used in advertising or sales promotion to indicate explicit or implicit endorsement of the product or material by the NCWM.



Cardinal Scale Manufacturing Co
Indicating Element / 855

Application: Non-Computing digital electronic indicating element for use with a NTEP certified and compatible weighing/load receiving element.

Identification: The capacity by division statement is marked on the front of the device adjacent to the weight display. All other required markings can be found on a label on the back of the indicator that will self-destruct if attempted to be removed.

Sealing: To access the Category 1 Audit trail: Press the Menu key; the display will show the “Settings Overview 1” screen. This screen shows both the Calibration (Cal=) and Configuration (Cfg=) audit trails. Press “Exit” on the menu to return to normal operation.

Test Conditions: The emphasis of the evaluation was on device design, marking, operation, performance, and compliance with influence factors. A Model 855 indicating element was submitted for evaluation. The 855 indicating element was interfaced to a Cardinal model EB-30 weighing/load receiving element (Certificate of Conformance 03-031) to verify compliance with zero, zone of uncertainty, and motion detection requirements. Additionally, the 855 was interfaced to a load cell simulator to perform several increasing / decreasing tests, warm-up test and power interrupt test. Voltage variation was performed at 85 VAC and 264 VAC and 6 VDC and 13.2 VDC. Temperature tests were performed over a range of -10 °C to 40 °C (14 °F to 104 °F).

Evaluated By: T. Buck, B. Stone (OH)

Type Evaluation Criteria Used: *Handbook 44 Specifications, Tolerances, and Other Technical Requirements for Weighing and Measuring Devices*, 2022 Edition. *NCWM Publication 14: Weighing Devices*, 2022 Edition.

Conclusion: The results of the evaluation and information provided by the manufacturer indicate the device complies with applicable requirements.

Information Reviewed By: D. Flocken (NCWM)

Example of Device:

